



State of Ohio
Weatherization Program
Standards

Section **MOBILE HOME MECHANICAL
SYSTEMS INSTALLATION**

Subject **Electrical Safety**

SERVICE ENTRY BOX/CIRCUITS 701-8.1

Have the electric utility company replace the main electrical supply if it is unsafe.

main power supply
701-8.1a

When needed, replace the main service panel according to the NEC considering amp size, number of circuits, and wire size of circuits.

main supply panel
701-8.1b

Circuit wiring must be installed in conformance to the NEC.

circuits
701-8.1c